







Attention: Read and understand these instructions before installing fixture. This fixture is intended for installation in accordance with the National Electric Code and local regulation. To assure full compliance with local codes and regulations, check with your local electrical inspector before installation. This equipment is guaranteed only when used as indicated in these instructions; therefore they should be kept for future reference. To prevent electrical shock, turn off power supply before carrying out any connection or maintenance operations. During installation, the LED chips may be exposed; please do not touch them to ensure proper long-term operation.

Note : Access above ceiling may be required for emergency driver maintenance or replacement.


STEP 1	<p>Make sure all pieces of the mounting are in the bag</p>	STEP 2	<p>Insert mounting bars into the proper openings on the side of the mounting frame.</p>
			
STEP 3	<p>For joist installation : 3.1 Align mounting bar with the bottom edge of the joist 3.2 Push on the built-in hook for wood joist or use screws to mount the frame on wood or metal joist</p>	STEP 4	<p>For grid ceiling: 4.1 Install mounting bar notches on the ceiling t-bar 4.2 Secure mounting bar to grid ceiling with metal wire</p>
			



STEP 5

- 5.1 Remove junction box cover
- 5.2 Remove pry-out knock out
- 5.3 Use BX conduit connector
- 5.4 Make appropriate electrical connection

- 5.5 Screw back junction box cover






STEP 6


Light switch box Installation close to mounting frame

- 6.1 Install light switch box (not included) close enough to connect with emergency driver flexible conduit.
- 6.2 Connect flexible conduit from emergency driver to light switch box.



STEP 7






Install light switch on faceplate.





STEP 8

- 8.1 Connect connectors.
8.2 Make connections with test switch.






STEP 9


Connection box installation remote from mounting frame

- 9.1 Connect emergency driver flexible conduit to a connection box.
- 9.2 Connect connectors
- 9.3 From the connection box send wires to the remote light switch box.



STEP 10


Install light switch on faceplate.





STEP 11

Make appropriate connections with test switch.



STEP 12

Ceiling cut out:

12.1 Make appropriate ceiling cut-out (23.15cm diameter)

12.2 Adjust mounting frame flush to ceiling by releasing mounting bracket butterfly nut inside the frame

12.3 Tighten mounting bracket butterfly nut inside the frame when the frame is flush to ceiling

